

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 1129

Date : 12/09/2025

It is certified that an inspection team headed by Mr. Ramesh
रमेश कुमार (Name of Officers
with designation) from नगर निगम कोटा दक्षिण (Name of
Department/Office) inspected the Sarvodaya Sr. Sec. School
Jagpura Kota (Name & Address of
the School) on 12/09/2025 and found that the Sarvodaya Sr. Sec.
School (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 Year.

Signature with Seal :

Name

Designation

रमेश
रमेश कुमार
स्वास्थ्य निरीक्षक
नगर निगम कोटा दक्षिण

To

Sarvodaya Sr. Sec. School
Jagpura Kota

(Name & Address of the Institution)



OFFICE OF THE SENIOR CHEMIST
REGIONAL LABORATORY, PHED, KOTA, RAJASTHAN
 PHED Campus, AKELGARH KOTA-324010



Test Report
(CHEMICAL & BACTERIOLOGICAL EXAMINATION OF WATER)

Desp. No. : 223

Dated : 20/5/26

Issued to:

Principal

Sarvodaya Sr. Sec. School, Jagpura
 Kota

District: Kota

Block/City: Kota

Sample No. Collected by Lab

Ref ID	24			Sample Code No.	PC-38 PB-30
Reference : Letter No.		NM		Source :	RO
Reference Date:		13.05.26		Source Location :	Jagpura Kota
Date of Receipt :		13.05.26		Habitation/Ward No. :	-
Sample ID	34				
Name of Sample Collector:		Mujjaffar Ali		Village/Colony/Nagar :	-
Designation of Sample Collector:		-		Gram Panchayat/City Area :	-
Latitude of Location				Date of Collection :	13.05.26
Longitude of Location				Start Date of Examination :	13.05.26
Elevation of Location				End Date of Examination :	20.05.26
Test Parameters		IS-10500:2012(RA 2023)		Sample Report No.	
		Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	References Method:	Test Values
1	pH At Temp. 25 ⁰ C	6.5 to 8.5	No relaxation	[IS 3025, P-11], 2022	8.01
2	Turbidity	1.0	5.0	-	0.36
3	Total Alkalinity (as CaCO ₃) mg/l	200	600	[IS 3025, P-23], 2023	60
4	Total Hardness (as CaCO ₃) mg/l	200	600	[IS 3025, P-21], 2009 (RA 2023)	50
5	Chloride (as Cl ⁻) mg/l	250	1000	[IS 3025, P-32], 2025	20
6	Nitrates (as NO ₃ ⁻) mg/l	45	No relaxation	[APHA, Ed24, 4500-B] NO3: 2023	2.0
7	Fluoride (as F ⁻) mg/l	1.0	1.5	[IS 3025, P-60], 2008 (RA 2023)	0.084
8	Total Dissolved Solids (TDS) mg/l At 180 ⁰ C	500	2000	[IS 3025 P-16]: 2023 /APHA, Ed24, 2510-B] Cond.2023	108
9	Total Coliform (MPN/100ml)	Nil	Nil	-	NIL

(*ADL= Above detection limit; BDL= Below detection limit)

**REPORT IS NOT VALID FOR
 JUDICIAL AND COMMERCIAL
 PURPOSE**

Authorized Signatory

 Senior Chemist
 PHED Reg. Lab. Kota

NOTE:

- This test report shall not be reproduce except in full, unless permission for the reproduction of an approved abstract has been obtained from the Senior Chemist, REGIONAL LABORATORY PHED, KOTA (Rajasthan).
- This test report reletes only to the samples/items submitted to the laboratory for test.
- This report is not valid for legal cases/legal purposes.
- Sample will be preserved only for 15 days from date of receipt.
- Measurement of uncertainty and standard methods will be provided to customer on demand.

Telephone : 0744-2470946

E-mail: lab.kot.phed@rajasthan.gov.in

-----End of the Report-----